



September 6, 2019

TO THE PROSPECTIVE BIDDER:

RE: Hartford Avenue Rehabilitation from SE 22<sup>nd</sup> Street to Cownie Soccer Complex  
Activity ID: 06-2019-017

We are issuing Addendum No. 2 on the above-referenced project. This Addendum No. 2 modifies, supplements, or replaces information contained in the contract documents. This addendum is hereby made a part of the contract documents.

Each bidder shall acknowledge receipt of each addendum in its proposal in order to have its bid read and considered. Acknowledgment of the receipt of each addendum shall be made by inserting the number of each addendum in the appropriate blank provided for such acknowledgment in the proposal.

The original proposal shall be used to bid this project.

The current bidders list is available on our web page:  
[www.dmgov.org/Departments/Engineering/Pages/ProjectBidInformation.aspx](http://www.dmgov.org/Departments/Engineering/Pages/ProjectBidInformation.aspx)

If you have any questions regarding this Addendum No. 2, please contact the Project Manager, Joseph Eddy at 515-283-4034.

Sincerely,

A handwritten signature in black ink that reads "Steven L. Naber". There is a small red mark or stamp to the right of the signature.

Steven L. Naber  
City Engineer

Attach.

**ADDENDUM NO. 2**  
**ON**  
**HARTFORD AVENUE FROM SE 22<sup>ND</sup> STREET TO COWNIE**  
**SOCCER REHABILITATION**  
ACTIVITY ID 06-2019-017

September 6, 2019

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
1	Plan Sheet C.01 Bid Item Modifications	1

**1. Plan Sheet C.01 Bid Item Modifications**

Sheet C.01 modifications include the following changes/clarifications to Bid Item Nos. 3 and 13.

ITEM NO. 3      CLEAN CRUSHED STONE (3")

This item can be either clean natural crushed limestone or clean crushed concrete conforming to the gradation described in SUDAS Section 2010, 2.04.B.1.

ITEM NO. 13      CLEAN CRUSHED STONE (3"), FOR OVER-EXCAVATION

This item can be either clean natural crushed limestone or clean crushed concrete conforming to the gradation described in SUDAS Section 2010, 2.04.B.1.

**End of Addendum No. 2**