



March 4, 2020

TO THE PROSPECTIVE BIDDER:

RE: Armory Parapet Tuckpoint  
Activity ID: 10-2020-003

We are issuing Addendum No. 1 on the above-referenced project. This Addendum No. 1 modifies, supplements, or replaces information contained in the contract documents. This addendum is hereby made a part of the contract documents.

Each bidder shall acknowledge receipt of each addendum in its proposal in order to have its bid read and considered. Acknowledgment of the receipt of each addendum shall be made by inserting the number of each addendum in the appropriate blank provided for such acknowledgment in the proposal.

The original proposal shall be used to bid this project.

The current bidders list is available on our web page:  
[www.dmgov.org/Departments/Engineering/Pages/ProjectBidInformation.aspx](http://www.dmgov.org/Departments/Engineering/Pages/ProjectBidInformation.aspx)

If you have any questions regarding this Addendum No. 1, please contact the Project Manager, Jill Tenney at 515-283-4032.

Sincerely,

A handwritten signature in black ink that reads "Steven L. Naber". To the right of the signature, the initials "RD" are written in red ink.

Steven L. Naber  
City Engineer

Attach.

**ADDENDUM NO. 1**  
**ON**  
**Armory Parapet Tuckpoint**  
**ACTIVITY ID 10-2020-003**

**March 4, 2020**

CLARIFICATIONS AND/OR CHANGES TO SPECIFICATIONS

Specification Section 04 03 43 Historic Stone Masonry Repointing

1. 2.2 Mortar Materials, CHANGE B. from "Factory-Prepared Lime Putty: ASTM C 1489 to "Hydrated Lime: ASTM C207, Type O."
2. ADD  
"F. Packaged Dry Material for Mortar for Unit Masonry: Premixed Portland cement, hydrated lime, and sand; capable of producing mortar of the specified strength in accordance with ASTM C270 with the addition of water only.
  1. Color: Mineral pigments added as required to produce approved color sample.
  2. Manufacturers:
    - a. SpecMix: Portland, Lime and Sand; Tuckpoint Mortar
    - b. Amerimix: AMX 420
    - c. Substitutions: See Section 01 60 00 – Product Requirements.

End of Addendum 1